

ADDENDUM # 2
PROJECT #2029

March 31, 2022

Village of Newcomerstown
New Administration Building
308 South College Street
Newcomerstown, OH 43832

V2 Architects, Inc.
903 Steubenville Avenue
Cambridge, Ohio 43725

To All Bidders:

This Addendum is issued to modify the original Project Manual and Drawings and is hereby made a part of the Contract Documents. This Addendum shall be attached to the Project Manual(s) in your possession and shall become a part of all bids. Bidders shall review changes to all portions of the work, as changes to one portion may affect the work of another. NOTIFY ALL SUBCONTRACTORS OF ADDENDUM ITEMS:

SPECIFICATIONS

ITEM 1 SECTION 088000 – GLAZING

- A. Remove article 1.6.D “Delegated-Design Submittal.”
- B. Remove article 1.8.B “Installer Qualifications.”

DRAWINGS

ITEM 2 SHEET H1.1 HVAC PLANS

- A. In room 115 Storage, remove each “SR-1” (5 total) and replace with a 6’ long branch of 8” diameter ductwork that terminates with diffuser “SD-1” in existing ceiling.
- B. EWH-1 to be “Raywall AFA840D-3” or equal.

END OF ADDENDUM